

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			I. CONTRACT ID CODE J	PAGE OF PAGES 1   2
2. AMENDMENT/MODIFICATION NO. 0005	3. EFFECTIVE DATE 13-Aug-2003	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)
6. ISSUED BY CONTRACTING DIVISION USAED, HONOLULU BLDG S230 (CA83) FT. SHAFTER HI 96858-5440	CODE DACA83	7. ADMINISTERED BY (If other than item 6) <b>See Item 6</b>		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. DACA83-03-B-0001	
		X	9B. DATED (SEE ITEM 11) 06-Jun-2003	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended.				
Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  FY03 MCA PN 48783 PHASE 2C1 WHOLE BARRACKS RENEWAL, SCHOFIELD BARRACKS, OAHU, HAWAII  (CONTINUED ON PAGE 2)				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL:	EMAIL:	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
_____ (Signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)		

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

1. CHANGES TO THE SOLICITATION. Attached hereto are revised pages to the solicitation. The revision mark “(Am-0005)” is shown on each revised page.

REVISED PROVISIONS/CLAUSES/PAGES. Following are revised pages to the solicitation. Changes are indicated in **bold** print. Although the entire sections are being re-issued under Am-0005, only the following pages/provisions/clauses changed in these sections.

Division 01 GENERAL REQUIREMENTS SECTION 01900

Paragraph 1.3.4 Project Superintendent.

The Project Superintendent shall have at least fifteen (15) years experience in managing and supervising construction projects of similar size and scope, preferably Department of Defense projects.

NEW PROVISIONS/CLAUSES/PAGES Following are added to the solicitation under Am-0005.

SECTION 00900

Additional Questions and Answers to this section (1 page)

2. The Bid Opening date is EXTENDED FROM: August 15, 2003 TO: August 19, 2003, 2:00 P.M. Hawaiian Standard Time.

Section 00900 Miscellaneous Attachments

ADDITIONAL QUESTIONS AND ANSWERS FOR DACA83-03-B-0001

Q44. Reference SX-2, SX-4. The column footing schedule on SX-2 indicates the width of column footing F-1 as 1329 mm. This does not match the scaled dimension shown on SX-4. Confirm the width should be 1829 mm.

A44. 1329 is a typo. 1829 mm is correct.

Q45. Reference SX-4, B/SX-10. B/SX-10 indicates a wall footing and stem wall along gridlines 1 and 6. SX-4 does not indicate a wall footing and stem wall along gridlines 1 and 6 between B and B.3 where the section cut occurs. Clarify whether a footing and stem wall are required.

A45. No footing and stem. Follow the plan SX-4

Q46. Reference SX-4, B/SX-10. SX-4 indicates a wall footing along gridlines 0 and 7 between A.9 and B.4. B/SX-10 does not indicate a wall footing. Clarify whether a wall footing is required. Is there a stem wall below the CMU walls located at gridlines 0/A.9, 0/B.4, 7/A.9 and 7/B.4?

A46. There is a stem and footing here. Follow the plan, SX-4.

Q47. Reference AX-4, SX-5. AX-4 indicates the wall along gridline B5 between 4.6 and 4.8 as non-structural (neither concrete nor CMU). SX-5 indicates this wall as concrete. Clarify the construction of this wall.

A47. This wall is concrete.

Q48. Reference D/SX-8, D/SX-12, 1,2,3/AX-13, 1/AX-15. D/SX-8 and D/SX-12 indicate a concrete beam B-3 on the CMU wall along gridlines 1 and 6. 1,2,3/AX-13 and 1/AX-15 do not show a concrete beam along the same gridlines. Clarify which sections to follow.

A48. In general, follow the structural details for structural elements.

Q49. The bid date, August 15, 2004, is a state of Hawaii holiday (Statehood Day) recognized as a holiday by electricians and roofers. This may affect availability of these subcontractors for the bid and, therefore, may result in less competitive pricing. Suggest moving the bid submission to another date.

A49. Bid opening date has been extended to August 19, 2003, 2:00 p.m. Hawaiian Standard Time, reference this Am-0005.

00900-8 (Am0005)

DACA83-03-B-0001