

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES 1 2	
2. AMENDMENT/MODIFICATION NO. AM-0003		3. EFFECTIVE DATE 6/14/04	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)	
6. ISSUED BY US Army Engineer District, Honolulu Corps of Engineers, Bldg S-200 Fort Shafter, HI 96858-5440 Contract Specialist: Kent Tamai		CODE	7. ADMINISTERED BY (If other than Item 6)		CODE

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State, and Zip Code)		(x)	9A. AMENDMENT OF SOLICITATION NO. W9128A-04-B-0003
		X	9B. DATED (SEE ITEM 11) 5/18/04
			10A. MODIFICATION OF CONTRACT/ORDER NO.
			10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE		

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

- (a) By completing Items 8 and 15, and returning ____ copies of the amendment;
- (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
- (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

(x)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return ____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

Kaunapau Harbor Breakwater Repair, Island of Lanai, Hawaii

See Page 2 of 2 Pages

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		BY (Signature of Contracting Officer)	

NSN 7540-01-152-8070

PREVIOUS EDITION UNUSABLE

30-105

STANDARD FORM 30 (Rev. 10-83)

Prescribed by GSA
FAR (48 CFR) 53.243

1. CHANGES TO THE SOLICITATION. Attached hereto is the new page to the solicitation. The revision mark "(AM-0003)" is shown on the page.

NEW PAGE.

The following page is added to the solicitation.

Section 00900 – Pages 00900-5

2. The bid opening date of June 18, 2004, 2:00 P.M., Hawaii Standard Time, remains unchanged.

SECTION 00900
RESPONSES TO QUESTIONS
SUBMITTED BY PLANHOLDERS
FOR
IFB NO. W9128A-04-B-0003

Questions from Russell Luke, Healy Tibbitts Builders, e-mail dated 6/13/04:

Q8. Reference Section 00700- 52.222-6:

In the Section 401 WQC Permit, section 3.c.(3)d.(10) lists the following requirement: "*Ensure that **silt curtain(s)** or other appropriate and effective silt containment device(s): be properly deployed prior to the commencement of any in-water construction work ...as demonstrated by the monitoring results.*"

Due to the deep water (up to 70') and the wave and surge conditions at the Kaumalapau breakwater site, it is highly unlikely that silt curtains can be successfully deployed and maintained. Are silt curtains actually required and if so can specifications be provided to guide the contractor on what type of silt curtains to use and how they should be deployed. We are unaware of any manufactured silt curtain that could survive the conditions at this site.

A8. The conditional Water Quality Certification permit specifies that silt curtain(s) or other appropriate silt containment devices be utilized. There is no requirement that deepwater silt curtains be utilized. Appropriate silt containment devices shall be deployed in the active construction areas and shall influence a minimum of six feet below the water surface, not to the depth of 70 feet. The method and type of silt containment devices will be proposed by the contractor and described in the contractor's submission to the State of Hawaii Department of Health in the Environmental Protection Plan (as described in the WQC permit, section c(1)(a)).